



DTLink Inc

Declaration Of Conformity

Products DTLink WDS UV Fire Detector, DTLink WDS Gateway, DTLink WDS Fire Cell

DTLink Inc herewith declares conformity of the above products with the respective requirements of the following regulations:

- i. Low-Voltage Equipment Directive 73/23/EEC
changed by 93/68/EEC
- ii. EMC Directive 89/336/EEC
changed by 91/263/EEC;92/31/EEC;93/68/EEC

The electrical safety of the products was evaluated based on the following standard:

- i. EN 6110-1:1993
Safety requirements for electrical equipment for measurement, control and laboratory use.
Part I: General requirements

The Electromagnetic Compatibility (EMC) of the products was evaluated based on the following standards:

- i. EN 50081-1:1992:
Electromagnetic Compatibility (EMC) – Generic emissions standard
Part 1: Residential, commercial and light industry
- ii. EN 50082-1:1992:
Electromagnetic Compatibility (EMC) – Generic immunity standard
Part 1: Residential, commercial and light industry
- iii. EN 61000-3:1998:
Electromagnetic Compatibility (EMC)
Part 3/Section 2: Limits for harmonic current emissions.

The Flame Detection performance of the products was evaluated based on the following standards:

- i. EN 54-10:2002 (on the high sensitivity setting)
Fire detection and fire alarm systems. Flame detectors. Point detectors.
Part 10 : Flame detectors – Point detectors

This declaration is issued by
DTLink Inc
2, place de la Taconnerie
CH – 1204 Geneva
by the CEO
Dimitri Tsiolis
October, 7, 2008

